



**JARSCO**  
**Utilities Inc.**  
 P.O. BOX 2276 SANTA CRUZ CA 95063  
 831.475.0143

# GAS LEAK SURVEY REPORT

Survey Date 8-12-15

ALIMUR M.H.P  
4300 SOQUEL DR  
SOQUEL, CA 95073

**PERSONNEL:** BRETT HIXSON

**SURVEY CONDITIONS:** DRY / CALM

**Type of Gas:**  Natural  Propane

**No. of Services:** 146

**No. of Anodeless Risers:** Ø

## Leak Classification and Action Criteria

- Grade 1** A LEAK THAT REPRESENTS AN EXISTING HAZARD TO PERSONS OR PROPERTY. REQUIRES **IMMEDIATE** REPAIR.
- Grade 2** A LEAK THAT IS RECOGNIZED AS NON-HAZARDOUS AT THE TIME OF DETECTION. REQUIRES **SCHEDULED** REPAIR.
- Grade 3** A LEAK THAT IS RECOGNIZED AS NON-HAZARDOUS AT THE TIME OF DETECTION. IF NOT REPAIRED, SHOULD BE **MONITORED ANNUALLY**.

<u>Equipment</u>	<u>Sensitivity</u>	<u>Alarm</u>
OVA 88	1 PPM - 10% Gas	3 PPM
CGI	.5% - 100% Gas	