



JARSCO
Utilities Inc.
 P.O. BOX 2276 SANTA CRUZ CA 95063
 831.475.0143

GAS LEAK SURVEY REPORT

Survey Date 8-12-15

ALIMUR M.H.P
4300 SOQUEL DR
SOQUEL, CA 95073

PERSONNEL: BRETT HIXSON

SURVEY CONDITIONS: DRY / CALM

Type of Gas: Natural Propane

No. of Services: 146

No. of Anodeless Risers: Ø

Leak Classification and Action Criteria

- Grade 1** A LEAK THAT REPRESENTS AN EXISTING HAZARD TO PERSONS OR PROPERTY. REQUIRES **IMMEDIATE** REPAIR.
- Grade 2** A LEAK THAT IS RECOGNIZED AS NON-HAZARDOUS AT THE TIME OF DETECTION. REQUIRES **SCHEDULED** REPAIR.
- Grade 3** A LEAK THAT IS RECOGNIZED AS NON-HAZARDOUS AT THE TIME OF DETECTION. IF NOT REPAIRED, SHOULD BE **MONITORED ANNUALLY**.

<u>Equipment</u>	<u>Sensitivity</u>	<u>Alarm</u>
OVA 88	1 PPM - 10% Gas	3 PPM
CGI	.5% - 100% Gas	